



Eastern Power
Distribution Company of A.P. Ltd
ఆంధ్ర ప్రదేశ్ విద్యుత్ పంపిణీ సంస్థ

From
The Deputy Executive Engineer
Operation :: Nallajerla

✓ To
The Executive Engineer,
Operation :: Tadepalligudem

Lr. No. DEE/OSD/NJL. /D.No. 88 /22, Dt. 05.02.2022

Sir,
Sub: - APEPDCL -OSD- Nallajerla- Erection of additional 150 KWp Solar roof top Arrangement in addition to the existing 350 KWp aggregating to a total 500 KWp SPV system at the premises of HT Consumer ELR465, M/s Sri Vasavi Educational Society, at P T Palli (V) in Neeladripuram Section of Nallajerla Sub- Division- Consumer side work completed - Necessary Approval for synchronization of solar power to Grid - requesting-Reg.

Ref: - Work completion letter received from M/s Vasavi Educational Society, P T Palli, received on 05.02.2022

&&&&&

It is to submit that HT Consumer ELR465, M/s Sri Vasavi Educational Society, at P.T.Palli (V) in Neeladripuram Section of Nallajerla Sub-Division has applied for additional 150 KWp Solar roof top Arrangement in addition to the existing 350 KWp aggregating to a total 500 KWp SPV system Solar Roof top at their premises and feasibility certificate also issued.


The consumer of ELR 465, M/s Sri Vasavi Educational Society, at P.T.Palli (V) in Neeladripuram Section of Nallajerla Sub-Division has represented that the work for additional 150 KWp Solar power plant was completed and requested for synchronization to Grid.

Accordingly, the premises is inspected along with the Executive Engineer/M&P/Tadepalligudem on 05.02.2022 and noticed that the consumer side work is completed and the consumer has provided all protective equipment of the SPV System as per the requirement of Indian & IEC Standards.

Hence, it is requested to accord necessary approval for synchronization of the above solar unit with grid please.

Encl: Work completion letter

Yours faithfully,


Deputy Executive Engineer
Operation:: Nallajerla.